

## **Tekelec 1000 AS Power Requirements**

Each T1000 AS server requires redundant power feeds with 15 Amp breakers; the power feed is 470W and 11.75 Amps at 40V. Ethernet switches and routers require 3 Amp breakers and 60W and 1.5 Amps at 40V. Console servers require 20W.